Residential New Construction - Revised Enbridge Gas Inspection Process – Effective Oct. 1, 2021

Call to Action – Ontario Builders and HVAC's

Builders will see **new internal Enbridge forms and labels** that will now be affixed during inspections. Our goal through this communication is to provide you advanced knowledge of what forms/labels are changing so that you are aware and informed as they begin to appear.

The Inspection Status Report will be replaced with a labeling process that identifies the inspection status of each appliance as follows:

THIS APPLIANCE INSTALLATION HAS BEEN INSPECTED AND APPROVED.
Date:
Address:
EGI technician's name: | Signature
DO NOT REMOVE LABEL
IS_L_008.2101
ENBRIDGE

Black Label - Appliance passes inspection: Enbridge will affix a black 'This Appliance Installation Has Been Inspected and Approved' label on all approved appliances.

DO NOT ACTIVATE APPLIANCE
Ontario regulation 212/01 requires that this appliance installation be approved by Enbridge Gas BEFORE being put into use.
Date: | Address:
Please visit enbridgegas.com/buildwithgas to have this appliance inspected prior to occupancy.
DO NOT REMOVE LABEL
IS_L_009.2101
ENBRIDGE

Red Label - Appliance not ready or fails inspection: When an appliance is not ready for inspection or an immediate hazard is identified, Enbridge will affix a red 'Do Not Activate Appliance' Label on the appliance.

Rejection Notice
ENBRIDGE

Rejection Notice: The Rejection Notice will be used where gas supply piping or an appliance is found to be not ready for inspection resulting in an immediate hazard. The appliance will be left off and this notice will be completed. An HVAC can not clear a Rejection Notice and a new Enbridge inspection will be required.

***The BTag Process has not changed.**

Have Questions or need Support?

You can email our technical support team here: Technical-Desk-VPC@enbridge.com

Or reach out to your representative at: Residential New Construction Team Contact Information